Energy performance certificate (EPC)

RGB Building Supplies Unit 4B Aspen Way PAIGNTON TQ4 7QR Energy rating

Valid until: 14 January 2031

Certificate number: 6101-2218-1904-3090-8141

Property type B8 Storage or Distribution


Total floor area 675 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If typical of the existing stock

If newly built

28 B

81 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	42.03
Primary energy use (kWh/m2 per year)	248

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/8252-6896-3859-9632-0775).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Philip Aston
Telephone	07966298014
Email	phil@astonenergysw.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO016817
Telephone	0330 124 9660
Email	certification@stroma.com

About this assessment

Employer	Aston Energy South West
Employer address	31 Dean Hill, Plymouth, Devon, PL9 9AF
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	15 January 2021
Date of certificate	15 January 2021